

29 October 2021



58 Kilmore Street  
PO Box 345  
Christchurch 8140

P. 03 365 3828  
F. 03 365 3194  
E. [ecinfo@ecan.govt.nz](mailto:ecinfo@ecan.govt.nz)

Customer Services  
P. 03 353 9007 or 0800 324 636  
[www.ecan.govt.nz](http://www.ecan.govt.nz)

Irricon Resource Solutions  
Limited (Ashburton) Attn To:  
Gary Rae PO Box 584  
**Ashburton 7740**

Dear Gary Rae

## **Request for Further Information**

**Response required by:** 19 November 2021

**Record Number/s:** CRC221846

**Applicant Name:** S W Haugh & K A Marriott-Haugh

**Activity Description:** to discharge onsite wastewater to land

As you are aware, Trinity White has been processing the above resource consent application.

The information listed in Attachment 1 to this letter is hereby requested under Section 92 of the Resource Management Act 1991 (the RMA). As this information is required in order to fully understand the potential effects of the proposal, we are unable to further process the application until it has been supplied.

The options available to you under Section 92A(1) of the RMA are summarised below. A response is required by 19 November 2021 - 15 working days. You must choose one of these options.

### **A. Supply the requested information by 19 November 2021 - 15 working days**

If the information can be easily collated and supplied by this date, please provide it in writing (via email is fine) to [trinity.white@pdp.co.nz](mailto:trinity.white@pdp.co.nz).

### **B. Agree in a written notice by 19 November 2021 - 15 working days to supply the information requested**

Sometimes technical information will take some time to collate or key contacts may not be immediately available. If you need more time to supply the information requested, please advise me in writing when you can provide the information. You can do this via email or letter.

### **C. Refuse in a written notice by 19 November 2021 - 15 working days to supply the requested information**

**If you choose not to provide the requested information by the above date, or any date subsequently agreed to by the Canterbury Regional Council, then your application must be publicly notified and may be declined.**

Public notification enables any member of the public, including potentially affected parties, to submit on your proposal. If submission/s are received on your application, then you can expect a hearing to be held. Information on [the notification process](#) and on the [likely costs](#) for notification and a hearing can be found on our website.

Please contact Trinity via email ([trinity.white@pdp.co.nz](mailto:trinity.white@pdp.co.nz)) or phone (021 469 415) if you have any questions.

Yours sincerely

A handwritten signature in black ink, appearing to read 'K Walker'.

**Kelly Walker**  
Senior Consents Planner

## **ATTACHMENT 1**

### **Information Requested under Section 92 of the Resource Management Act 1991**

**Application Number/s: CRC221846**

**Date: 29.10.2021**

---

#### **1. Effect of discharge of nitrate nitrogen and pathogens on nearby groundwater users**

Background water quality information from wells in the area suggest that Ministry of Health Maximum Allowable Values for nitrate nitrogen and pathogens are already exceeded. Properties downgradient of the applicant's site use onsite bores for drinking water and given the elevated contaminant levels within the area:

- a. Please provide a quantitative assessment of the effect of the discharge from the maximum proposed volume on nitrate nitrogen levels in downgradient wells used for drinking water supply.
- b. Please provide a quantitative assessment of the effect of the discharge from the maximum proposed volume on pathogen levels in downgradient wells used for drinking water supply.
- c. Please include the references used to make this assessment and provide separate assessments for the proposed dripline or sand trench land application systems.